



Product Service

Attestation of Conformity

No. N8A 118725 0002 Rev. 00

Holder of Certificate: **EKOTEC ENERJI ITH.IHR.PAZ.SAN.VE.TIC. LTD.STI.**

Caykisla mah.D100 Yan Yol Cad. No:272
Bekirpasa Erenler
54200 Sakarya
TÜRKIYE

Product: **Heat pumps**
Heat pump

Brand: **EKOTEC**

Model(s): **1) ETHI-14M;**
2) ETHI-16M;
3) ETHI-18M

Parameters: Rated voltage: 220-240V~
Rated frequency: 50Hz
Rated input power: 1) 6000W, 2) 6900W, 3) 7400W
Rated current: 1) 28A, 2) 32A, 3) 34A
Protection class: I
Degree of protection: IPX4
Refrigerant: R410A

Tested according to: EN 60335-2-40:2003/A13:2012
EN 60335-1:2012/A15:2021
EN 62233:2008

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 701282213002-00

Date, 2022-11-02

(Mingmin Fan)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.